



DASMA
Door & Access Systems
Manufacturers Association
International

GATE OPERATOR & ACCESS CONTROL POINT SYSTEMS DIVISION

TECHNICAL DATA SHEET

#371

1300 Sumner Avenue
Cleveland, Ohio 44115-2851
Phone: 216-241-7333 • Fax: 216-241-0105
E-mail: dasma@dasma.com

Automated Vehicular Gate Systems: Checklist for Inspectors and Property Owners

DASMA has developed a checklist to assist inspectors and owners of automated vehicular gate systems, which are typically a very large moving item on a property. It is important that such systems be in good operating condition, and the checklist is intended as an aid in checking the principal elements of gate systems.

Do not repair or adjust gate systems yourself. Contact a trained gate systems technician with any questions or to make any repairs or adjustments.

Please note that the checklist is intended to be a summary of many important automated vehicular gate aspects, but may not inclusively identify all potential hazards of every specific gate system installation.

See the following pages for a copy of the checklist.

Note: Technical Data Sheets are information tools only and should not be used as substitutes for instructions from individual manufacturers. Always consult with individual manufacturers for specific recommendations for their products and check the applicable local regulations.

This Technical Data Sheet was prepared by the members of DASMA's Operator & Electronics Division Technical Committee. DASMA is a trade association comprising manufacturers of rolling doors, fire doors, grilles, counter shutters, sheet doors, and related products; upward-acting residential and commercial garage doors; operating devices for garage doors and gates, sensing devices, and electronic remote controls for garage doors and gate operators; as well as companies that manufacture or supply either raw materials or significant components used in the manufacture and installation of the Active Members' products.

Automated Vehicular Gate Systems: Checklist for Inspectors and Property Owners

Instructions: A vehicular gate is typically a very large moving item on a property. It is important that it be in good operating condition and installed according to manufacturer's instructions. Using this checklist, in conjunction with the DASMA Gate Systems Safety Brochure (<http://www.dasma.com/pdf/publications/brochures/GateSystemsSafetyBrochure.pdf>) will help you to check the principal elements of the gate system. Mark each item with a check mark ("✓") to indicate "pass", with an "X" to indicate "fail", or with a line "---" to indicate "not applicable". Do not repair or adjust the gate system yourself. Contact a trained gate systems technician with any questions or to make any repairs or adjustments.

Please note that the checklist is intended to be a summary of many important automated vehicular gate aspects, but may not inclusively identify all potential hazards of every specific gate system installation.

Items for Inspectors to Check

| Item | Description | Pass | Fail | N/A |
|------------------------------------|---|-------------|-------------|------------|
| Visual Inspection Gate System | Visually inspect the rollers, fasteners, brackets and other gate hardware for proper alignment, proper tightness, and signs of damage, breakage, looseness, rust or wear. Moving parts should be lubricated and should not be squeaking. Visually inspect wiring for fraying or exposure. Verify that the system has in place two means of entrapment protection at each point where an entrapment hazard exists. Typical means of entrapment protection are inherent entrapment (built into the operator), edge sensors, or photoelectric eyes. Other means are possible. For more information see the manufacturer's instructions. | | | |
| Operator Listing Label | See if the operator has a listing label indicating conformance to UL 325. | | | |
| Controls Placement | Check if placement of user operational controls is six or more feet from the gate. | | | |
| Manufacturing Date of Operator | Gate operators manufactured before March, 2000 may not have adequate safety provisions. If a homeowner does not allow disconnection at the time of inspection, such an operator should be flagged as an item that must be either inspected by a trained gate systems technician or removed / replaced / disconnected and taken out of service. Replacement is the preferred option. | | | |
| Gate Fall-over and Roller Guarding | Check if there is a means to prevent the gate from falling over in the event of the failure of the gate rollers or hinge. Ensure all rollers are guarded or covered to eliminate possibility of a finger being inserted between roller and gate. | | | |
| Electric Operation | Begin with the gate fully closed. Cause the gate to fully open and fully close. Watch and listen for any irregularities in operation, e.g. uneven speed, excessive sway, unusual stopping, etc. | | | |
| Edge Sensor | When a gate has an edge sensor, inspect the sensor and wiring for cracks, breaks, holes, crimps or other physical damage. Check mounting location(s) with respect to reducing the risk of entrapment protection in both directions of gate travel. Check edge sensor for proper operation (see Contact Reverse Test) | | | |
| Photoelectric Sensors | When a gate has photoelectric sensors, inspect wiring and reflectors for signs of cracking, breakage, looseness or wear. Check mounting location(s) with respect to reducing the risk of entrapment protection in both directions of gate travel. Check for proper operation (see Non-Contact Reverse Test) | | | |

Note: Technical Data Sheets are information tools only and should not be used as substitutes for instructions from individual manufacturers. Always consult with individual manufacturers for specific recommendations for their products and check the applicable local regulations.

This Technical Data Sheet was prepared by the members of DASMA's Operator & Electronics Division Technical Committee. DASMA is a trade association comprising manufacturers of rolling doors, fire doors, grilles, counter shutters, sheet doors, and related products; upward-acting residential and commercial garage doors; operating devices for garage doors and gates, sensing devices, and electronic remote controls for garage doors and gate operators; as well as companies that manufacture or supply either raw materials or significant components used in the manufacture and installation of the Active Members' products.

TECHNICAL DATA SHEET

#371

| | | | | |
|--|--|--|--|--|
| Contact Reverse Test | Perform the following test on (1) vertical frame member(s) and (2) each vertical edge sensor provided (if any): Begin with the gate in the fully open position. Standing just outside the path of the gate at a location where entrapment is likely to occur, cause the gate to close. As the gate is closing, firmly press a solid object against a gate frame member (or edge sensor) in the direction opposing the travel of the gate. The gate should stop within 2 seconds and then reverse at least 2 inches. Repeat this test, while opening the gate, starting from the fully closed position. | | | |
| Non-Contact Reverse Test | If the gate has a non-contact sensing device protecting the path of a closing gate, perform the following test: Begin with the gate fully open. Standing just outside the path of the gate, cause the gate to close. Pass an object across the path of the sensing beam as the gate is closing. The gate must stop within 2 seconds and may reverse if so designed. If a non-contact sensor protects the path of an opening gate, repeat starting with the gate in the fully closed position. | | | |
| Safety / Warning Signs | Safety / Warning signs must be installed in such a way that they are visible from each side of the gate – whether the gate is open or closed. | | | |
| Openings in gate and fence (horizontal slide gate) | Measure the maximum size opening in the gate and that portion of a fence the gate covers when fully open. Openings must be 2 ¼” or less from the bottom of the gate up to a minimum of 72” above the ground or to the top of the gate, whichever is less. | | | |
| Barbed Wire / Barbed Tape, & Protrusions | Estimate the height above grade of barbed wire/tape, if used. Height of barbed wire should be 6’ minimum, and barbed tape should be 8’ minimum. IMPORTANT: Do not touch barbed wire or tape. Any protrusions on the leading, trailing, and bottom edges of the gate must be less than ½” and smooth on all surfaces with no sharp edges. | | | |
| Manual Release | Ensure the gate operator has a method to allow the gate to be manually operated. | | | |
| Manual Operation | Begin with the gate fully closed. Actuate the manual release for the operator per the manufacturer’s written instructions. Carefully open and close the gate for one full cycle. The gate should operate smoothly. Reconnect the operator and note any problems encountered in that process. | | | |
| Pedestrian Access | Verify that separate pedestrian access is provided or available, and that the access is such that a pedestrian will not come in contact with the moving gate during its entire length of travel. | | | |

By signing this inspection checklist, I/we hereby certify that each item listed and checked above has been examined by the inspector and is clearly understood by the customer.

Customer Signature: _____

Date _____

Inspector Signature _____

Date _____

DASMA has developed a brochure that provides information about safe gate ownership and operation. Visit the DASMA website, www.dasma.com, to obtain a copy online, contact DASMA at 216-241-7333, or e-mail DASMA at dasma@dasma.com.

Note: Technical Data Sheets are information tools only and should not be used as substitutes for instructions from individual manufacturers. Always consult with individual manufacturers for specific recommendations for their products and check the applicable local regulations.

This Technical Data Sheet was prepared by the members of DASMA's Operator & Electronics Division Technical Committee. DASMA is a trade association comprising manufacturers of rolling doors, fire doors, grilles, counter shutters, sheet doors, and related products; upward-acting residential and commercial garage doors; operating devices for garage doors and gates, sensing devices, and electronic remote controls for garage doors and gate operators; as well as companies that manufacture or supply either raw materials or significant components used in the manufacture and installation of the Active Members' products.